

Department of Public Safety & Corrections
State of Louisiana

JOHN BEL EDWARDS
GOVERNOR




JAMES M. LE BLANC
SECRETARY

May 6, 2022

MEMORANDUM

TO: The Honorable Mark Herford
Sheriff of Beauregard Parish

FROM: 
James M. Le Blanc
Secretary

RE: "Basic Jail Guidelines" Monitoring Report

Please see the attached monitoring report regarding the Basic Jail Guidelines (BJG) annual inspection that was conducted at Beauregard Parish Jail on December 1, 2021.

There were significant issues reported by the Fire Marshal and DHH. We have been informed the facility is in the process of making improvements and renovations to areas of concern. As of February 2022, no offenders (DOC included) have been housed at this facility.

Once renovation and repairs are completed, a follow up inspection shall be conducted before any DOC offenders return to Beauregard Parish Jail. Major Chad Firmin, BJB Team Leader, shall be kept up to date on the facilities corrective actions throughout the improvement and renovation progress.

Thank you for your support of the BJB process.

JML/mw

Attachment

c: Mike Ranatza, Executive Director, Louisiana Sheriffs' Association
Freddie Doyle, Warden, Beauregard Parish Jail
Seth Smith, Chief of Operations
Marcus Myers, Warden
Chad Firmin, BJB Team Leader



BJG MONITORING REPORT
(Annual, Semi-Annual, Quarterly, Monthly or Recert with Waiver)

FACILITY NAME: Beaugard Parish Jail
BJG MONITORS: Major Chad Firmin Team Leader
TYPE OF INSPECTION: Annual Monitoring with waiver
FACILITY STAFF: Warden Freddie Doyle
BJG INSPECTION DATE: December 01, 2021
PREVIOUS BJD INSPECTION DATE: June 26, 2019
OPERATIONAL CAPACITY: 161
COUNT ON DAY OF VISIT: 132

CONCERNS OR ISSUES FROM THE PREVIOUS BJD MONITORING INSPECTION:

None

	# MALE	# FEMALE	TOTAL
Number of DOC Offenders	10	0	10
Number of Local Offenders	120	2	122
Number of Out of State Offenders	0	0	0
Number of Federal Offenders	0	0	0
Number of ICE Detainees	0	0	0
TOTAL	130	2	132

of DOC Offenders that are:

Single Bunked 0
Double Bunked 10
Triple Bunked 0
Total 10

of DOC Offenders that are in restricted housing:

Single Bunked 0
Double Bunked 0
Triple Bunked 0
Total 0

Assaults (Please list monthly since the previous BJG monitoring visit.)

Month/Year	Off/Off	Off/Off w/sig inj	Offender/Staff	Off/Staff w/sig inj
December 2020	0	0	0	0
January 2021	1	0	1	0
February 2021	0	0	0	0
March 2021	0	0	0	0
April 2021	0	0	0	0
May 2021	0	0	0	0
June 2021	0	0	0	0
July 2021	0	0	0	0
August 2021	0	0	0	0
September 2021	0	0	0	0
October 2021	0	0	0	0
November 2021	0	0	0	0

Seizure Findings (Please list monthly since the previous BJG monitoring visit.)

Month/Year	Illicit Substance	Alcohol	Weapon	Cell Phone	Other
December 2020	0	0	0	0	0
January 2021	0	0	0	0	0
February 2021	0	0	0	0	0
March 2021	0	0	0	0	0
April 2021	0	0	0	0	0
May 2021	0	0	0	0	0
June 2021	0	0	0	0	0
July 2021	0	0	0	0	0
August 2021	0	0	0	0	1 tattoo gun
September 2021	0	0	0	0	0
October 2021	0	0	0	0	0
November 2021	0	0	0	0	0

GENERAL APPEARANCE/CLEANLINESS/COMMENTS OF THE FACILITY:

Living Area

Dorms:

Dorm areas had some trash and needs some cleaning. Offender beds have a mattress and linens. Offender personal property is not stored properly and belongings all around bed area.

Cell Block:

The cell area had some trash and empty food trays and needs some cleaning and used for pre-trial offenders, medical purposes and suicide watches if needed. There were no DOC offenders housed in lockdown cells. Some cells have new cells doors that have replaced the old cell doors.

Culinary/Dining:

The facility does not have a dining hall. Meals are prepared and sent to the housing areas in food carts. Kitchen utensils are on inventory and stored in a locked cabinet and signed in and out.

Bathrooms:

Bathrooms and showers need cleaning. Peeling paint and rust in shower areas. Adequate hot water available for offender use. All offenders have access to bathroom and showers without having security assistance.

Yard Areas:

The yard area is neat and clean. Offenders have access to the yard for recreation.

Maintenance:

Maintenance is done by the Police Jury and not located on the jail grounds. Repairs are in the process of being scheduled to be done throughout the entire facility by the Police Jury and violations addressed as noted in the DHH and FM reports.

REVIEW AND COMMENT ON THE FOLLOWING BASIC JAIL GUIDELINES: *(Compliant or Non-Compliant)*

- I-A-001 Safety/Sanitation/Inspections- Non-Compliant**
Safety and sanitation inspections are being conducted throughout the facility. The latest Fire Marshal Inspection was done 11/22/2021, DHH Inspection for the Jail was done 6/16/2021 with noted discrepancies that were not addressed as of the audit. In early 2022 the facility will be sending its offenders to another facility to renovate and make repairs to the facility and address the noted violations.
- I-C-001 Emergency Plan-Compliant**
Facility has emergency plans in place and will be submitted to the Fire Marshal for approval for the year of 2022.
- II-A-007 Counts-Compliant**
- *How many formal counts are conducted each shift? Two counts formal per shift*
 - *How many counts are conducted each day? 4 counts*
- Stick outs are counts that are conducted in areas other than housing units, such as food services and other areas of normally authorized locations. When conducting and submitting the counts, employees are to actually see the offender before turning in these counts.***
- *How does the facility accomplish this? Staff physically count offenders not in housing units during count and call into control.*
 - *Does this process insure accountability and safe/secure operation of the facility? Yes*
- II-A-008 Offender Population Management System-Compliant**
A list of offenders housed at the facility is kept along with the location of offenders. A digital log is kept on the computer at the jail.
- II-A-010 Admissions-Compliant**
Offender property searched and signed for during admission process. Photos and fingerprinting done upon admission process. Booking checklist conducted and offenders sign for handbook during admissions.
- II-A-012 Classification System-Compliant**
Does this facility have any trustees that work outside the secure perimeter? (Yes or No) Yes
If yes,
- *What is their classification process to determine who is eligible for trustee status? An offender fills an application for trustee and send to the Warden for review. The Warden will review criminal history, time being served, disciplinary record to be considered for trustee.*

- *Does their classification process meet DPS&C, Corrections Services' criteria?*
Yes

II-A-018 Offender Drug Testing *(Please list monthly since the previous BJG monitoring visit.)*

Month/Year	# DOC Tested	Total DOC Pop	% Tested	# Positive
December 2020	2	17	12	0
January 2021	2	15	13	0
February 2021	3	30	10	0
March 2021	3	4	75	0
April 2021	3	30	10	0
May 2021	3	29	10	0
June 2021	2	9	22	0
July 2021	2	10	20	0
August 2021	2	10	20	0
September 2021	2	15	13	0
October 2021	2	21	9	0
November 2021	2	17	12	0

II-A-019 Offender Transfers-Compliant
Offender transfers are done according to policy.

II-A-020 Frequency of Cell Checks-Compliant
Officers make rounds at least once every hour unless an offender is placed in a single cell on watch then the officer makes rounds every 15 minutes.

II-B-002-1 Use of Restraints for Pregnant Offenders-Compliant
The facility has a policy in place but does not house pregnant female offenders.

II-C-001 Procedures for Searches-Compliant
Searches are being conducted on offenders and their property and documented.

II-D-001 Key, Tool and Utensil Control-Compliant
The kitchen utensils are on inventory and signed in and out. Keys are in a locked area in the control area.

III-A-001 Rules and Discipline-Compliant
Facility has offender handbook that is given during intake process.

- *Does the facility's offender orientation include the application process for applying for restoration of good time? Yes*
- *What is their restoration of good time application process for the offender population? An offender will request the paperwork to restore good time. Once the paperwork is filled out it will be sent to the Wardens office where it will be reviewed and verified. Once signed it will be sent to DPS&C.*
- *Does their restoration of good time application process meet DPS&C, Corrections Services' criteria? Yes*

IV-C-001 Access to Care/Clinical Services *(Does the facility charge a co-payment? If so, approved by DPS&C?)*
Compliant- Facility does charge co-pays to DOC offenders that is approved by DPS&C

IV-C-006-1 Pregnancy Management-Compliant
Facility has policy in place but does not house pregnant females.

- IV-C-008 Annual TB Testing-Compliant**
TB testing is done annually.
- IV-C-012 Access to Sick Call-Compliant**
Offenders can access sick call 3 days a week on Monday, Wednesday and Friday.
- IV-C-013 Infirmary Care-Compliant**
The jail does not have an infirmary. The offenders are seen by the nurse at the jail. If further treatment is needed then they are taken to a local doctor or ER.
- IV-C-013-1 Medical Releases (Medical Parole, Medical Treatment Furlough, Compassionate Release) Compliant**
There have been no medical releases from the jail as of this date.
- IV-C-014 Suicide Prevention and Intervention-Compliant**
Policies in place and staff being trained on suicide prevention. If needed mental health services are out sourced through a local mental health provider.
- IV-C-016 Notification-Compliant**
Emergency contact information is gathered during admissions. No offender has been Admitted to ICU as of this date for family to be notified.
- IV-D-004 Confidentiality of Health Information-Compliant**
All medical records are kept confidential and secured in the nurses' station at the jail.
- IV-E-001 Alleged and Substantiated Sexual Assaults-Compliant**
- *Is this facility required to be PREA compliant due to contract language? (Yes or No) No*
 - *Is this facility PREA compliant? (Yes or No) No*
If yes, date compliance received:
 - *If this facility is required to be PREA compliant due to contract language, and has not done so, what is their plan of action for compliance? No*
- V-A-003 Programs and Services-Compliant**
- **List all Certified Treatment Programs** (Attach Form B-04-003-B)
None
 - **List all other Offender Programs**
Church Services on Sundays
- V-A-003-1 Educational Programming-Complaint**
There are no programs offered at the jail at this time

GED Program

Number of GED Slots	<u>20</u>
Number of Participants	<u>0</u>
YTD Number of Completions	<u>0</u>

- V-B-001 Releasing Offenders-Compliant**
DOC offenders are not normally kept at the jail therefore do not release from the jail.
- V-B-010 Proposed Expansions-Compliant**
There are no proposed expansions at this time.
- V-C-001 Substance Abuse Programs-Compliant**
AA/NA program offered. Overcomers Recovery is not being offered at this time. The jail is in the process of getting that program started again.
- V-C-002 Reentry Programs (Are offenders releasing with two valid forms of identification?)Compliant**
No re-entry programs offered at the jail. DOC offenders are not housed long at the jail for such programs.
- V-C-004 Parole Board Procedures-Compliant**
Staff attend parole board hearings and present any information to the board. There has been no DOC offenders up for parole this year from the jail.
- VI-B-002 Grievance Process-Compliant**
- *Does grievance process include at least two levels of review?*
Yes
 - *Who is the designee at each level of review?*
1st A/Warden, 2nd Warden, 3rd Sheriff
 - *What is the specified time period for response at each level?*
1st 15 days, 2nd 25 days, 3rd 40 days
- VII-A-002 Weapons Training-Compliant**
Employees are trained annually.
- VII-B-008 Monthly Reporting-Compliant**
Monthly reports are being done in a timely manner.

STAFF COMMENTS/MORALE/GENERAL OBSERVATIONS:

Spoke to staff on the day of the audit. Staff morale appeared to be good and employees are knowledgeable of job duties.

OFFENDER COMMENTS/MORALE/QUALITY OF LIFE:

Spoke to DOC offenders at the jail. Quality of life and offender morale appeared good. There were no problems or concerns voiced by offenders during the walk through.

RECOMMENDATION:

At this time, a follow up monitoring visit is recommended once the facility makes renovations and repairs to areas of concern noted as violations on FM and DHH inspection reports. The facility is in the process of making improvements and renovations to areas of concern throughout the jail and correcting the violations on the DHH and FM reports. As of February 2022 the facility has begun the renovation project and no offenders are housed at the facility at this time. The proposed time frame of work to be completed and the offenders back at the jail could be around July or August 2022.



**STATE OF LOUISIANA
DEPARTMENT OF HEALTH
OFFICE OF PUBLIC HEALTH**

**Detention or Incarceration
Notice of Violations**

Routine/Renewal

Permit Number 06-01-224	Permit Name Beauregard Parish Jail-224	
Name of Establishment Beauregard Parish Jail-224	Owner Name	
Address 412 BOLIVAR BISHOP DR DERIDDER, LA 70634	Date 12/08/2021	Time 12:00 PM

LAC TITLE 51 PART XVIII

CRITICAL ITEMS: These items MUST BE CORRECTED IMMEDIATELY (see compliance schedule below). Repeat violations may lead to enforcement actions or permit suspensions.

Category	Code Reference	Description of Violations
Handwashing Lavatories	101	12 - *There is no hot water at the hand lavatory.
Toilet Facilities	101	18 - *The toilets are in disrepair.
Approved Bathing Facilities	101	21 - *There is no hot water at the shower.
Safe Drinking Water	101	26 - *There is no drinking water available to some of the individual cells.

NON-CRITICAL ITEMS: These items should be corrected by the next regular inspection or according to the compliance schedule (see below) established by this office.

Category	Code Reference	Description of Violations
Building Requirement	101	3 - The walls are in disrepair.
Building Requirement	101	4 - The walls are not smooth and easily cleanable.
Building Requirement	101	6 - The ceilings are not in good repair.
Building Requirement	101	7 - There is peeling paint on the walls in the shower.
Insect and Rodent Protection	101	8 - All outer openings are not properly protected against the entrance of insects/rodents.
Handwashing Lavatories	101	16 - The hand lavatory is in disrepair.
Lighting	101	27 - There is less than 20 foot-candles of lighting in the cell block area.
Lighting	101	28 - There is less than 20 foot-candles of lighting in the shower area.
Lighting	101	29 - There is less than 20 foot-candles of lighting in the restroom area.
Lighting	101	30 - There is less than 20 foot-candles of lighting in the hallway/stairs area.

Comments:

Freddie Doyle- Warden
 Luke Gaspard-Assistant Warden
 Bryan McReynolds-Beauregard Parish Police Jury
 Email report to jgaspard@bpsheiff.org; fdoylejr@bpsheiff.org; bryanm@beauparish.org

Mop sink-no backflow prevention device on hose
 Women quarters- no adequate lighting; showers not clean; peeling paint; no hot water; walls not in good repair
 Holding-inadequate lighting; showers not clean; peeling paint; no hot water; walls not in good repair
 A block- inadequate lighting; showers not clean; peeling paint; no hot water; walls not in good repair
 B block- inadequate lighting; showers not clean; peeling paint; no hot water; walls not in good repair
 C block-inadequate lighting; showers not clean; peeling paint; no hot water; walls not in good repair
 D block—in adequate lighting; showers not clean; peeling paint; no hot water; walls not in good repair
 trustees 2nd floor-shower overflowing onto floor and dripping through floor into kitchen

Cells were no secured throughout facility; the doors throughout do not lock.
Several cells did not have adequate water pressure at sink.
The shower rubber mats are not clean
There are blankets/towels under rubber mats in shower areas.

Extended time given as per sanitarian supervisor.

Number Licensed For 168	Number in Attendance 137	License Anniversary 05/31/2021	
Sanitarian Name/Print Kayli Hyatt	Phone # 337-463-4486 ext. 239	Sanitarian Signature <i>KH</i>	R.S. # T1274

The above mentioned violations were called to my attention and were explained to me in detail. I hereby agree to

Correct Critical Violations by 12/13/2021

Correct Non-Critical Violations by 03/31/2022

Name/Title
Freddie Doyle/ Warden

Signature of Recipient

Freddie Doyle

STATE OF LOUISIANA
DEPARTMENT OF HEALTH
OFFICE OF PUBLIC HEALTH

INSTITUTION REPORT

Agency License No. N/A	Anniversary Month MAY				
Name of Establishment BEAUREGARD PARISH JAIL-224	Mailing Address				
Address 412 BOLIVAR BISHOP DR					
City, state, Zip Code DERIDDER LA 70634					
Type of Facility JAILS 168 137					
Parish Beauregard	Date Inspected 12/08/2021				
<p>The above establishment has been inspected by a representative of this section, and:</p> <p style="margin-left: 40px;">License is Recommended;</p> <p style="margin-left: 40px;">License is Not Recommended;</p> <p style="margin-left: 40px;">License is Pending Reinspection;</p> <p>from the standpoint of sanitation</p>					
<p>KAYLI HYATT</p> <div style="display: flex; justify-content: flex-end; align-items: center;"> <div style="border-bottom: 1px solid black; width: 200px; margin-right: 10px;"></div> <table border="1" style="border-collapse: collapse; text-align: center;"> <tr> <td style="width: 20px; height: 20px;"></td> <td style="width: 20px; height: 20px;"></td> <td style="width: 20px; height: 20px;"></td> <td style="width: 20px; height: 20px;"></td> </tr> </table> </div>					
<p>LHS 48 (R 7/89) D 1014</p>					



**STATE OF LOUISIANA
DEPARTMENT OF HEALTH
OFFICE OF PUBLIC HEALTH**

**Retail Food
Notice of Violations**

Routine/Renewal

Permit Number 06-0001006-1	Permit Name BEAUREGARD PARISH JAIL Public Eating Establishment	
Name of Establishment BEAUREGARD PARISH JAIL	Owner Name BEAU PARISH POLICE JURY	
Address 412 BOLIVAR BISHOP DR DERIDDER, LA 70634	Date 12/08/2021	Time 12:00 PM

LAC TITLE 51 PART XXIII

CRITICAL ITEMS: These items **MUST BE CORRECTED IMMEDIATELY** (see compliance schedule below). Repeat violations may lead to enforcement actions or permit suspensions.

Category	Code Reference	Description of Violations
WATER/SEWAGE	3101	44 - 3101 - The plumbing system is not sized and installed in accordance with Chapter XIV of the State Sanitary Code.

NON-CRITICAL ITEMS: These items should be corrected by the next regular inspection or according to the compliance schedule (see below) established by this office.

Category	Code Reference	Description of Violations
UTENSILS/EQUIPMENT/SINGLE SERVICE	2101	67 - 2101.1 - Non-food contact equipment is not maintained in good repair. Freezer. Cooler handles. [Repeat]
UTENSILS/EQUIPMENT/SINGLE SERVICE	2115	70 - 2115 - Single-service and single-use articles are reused
UTENSILS/EQUIPMENT/SINGLE SERVICE	2501	75 - 2501.2 - Non-food contact surfaces of equipment have an accumulation of dust, dirt, food residue and other debris. Freezer.
STRUCTURAL/DESIGN/MAINTENANCE/PLUMBING	3505	103 - 3505.1 - Openings are not protected against the entry of rodents or insects. Doors exiting back area.
STRUCTURAL/DESIGN/MAINTENANCE/PLUMBING	3701	105 - 3701.6 - Floor is not maintained in good repair.
STRUCTURAL/DESIGN/MAINTENANCE/PLUMBING	3703	106 - 3703.4 - Walls/ceilings or attached equipment are not in good repair.
STRUCTURAL/DESIGN/MAINTENANCE/PLUMBING	4105	109 - 4105.2 - Lockers or suitable facilities are not provided / used for storage of employees personal items, clothing and other possessions. Jacket hanging on the shelving near the walkin cooler and freezer.

Comments:


Freddie Doyle- Warden
 Luke Gaspard-Assistant Warden
 Email report to jgaspard@bpsheriff.org; fdoylej@bpsheriff.org
 Extended time given per supervisor.

NOTICE RS 40:31.38 (ACT 66)

RS 40:31.38 (ACT 66) authorizes the Louisiana Department of Health to charge a fee of \$150 to any permitted food establishment that fails to correct the necessary sanitary code violations to be in compliance at the time of its follow up inspection (1st re-inspection). Re-inspections are required when there are five or more uncorrected non-critical violations and/or one or more uncorrected critical violations remaining at the conclusion of an inspection. The fee is only charged if the necessary violations are not corrected before the 2nd re-inspection and other subsequent re-inspections. Establishments can avoid this fee if the violations noted on the routine inspection report are corrected by, or during, the follow up inspection. If a fee is assessed, the \$150 fee is payable within 30 days' notice, and failure to pay shall result in revocation of the permit.

Sanitarian Name/Print
Kayli Hyatt

Phone #
337-463-4486 ext. 239

Sanitarian Signature


R.S. #
T1274

The above mentioned violations were called to my attention and were explained to me in detail. I hereby agree to

Correct Critical Violations by 12/13/2021

Correct Non-Critical Violations by 03/31/2022

Name/Title
Freddie Doyle- Warden

Signature of Recipient



FIRE MARSHALL REPORT

- 1. SPRINKLER SYSTEM – THE SYSTEM WAS DOWN AND NONE WERE WORKING. WE JUST SPEND \$8,000 AND HAD ALL FIRE SPRINKLERS REPLACED.**
- 2. FIRE PANEL – THIS RUNS ALL THE EMERGENCY PULL LEVERS MOUNTED ON THE WALL IN CASE OF A FIRE AND ALSO RUNS THE SMOKE DETECTORS. AT THIS MOMENT, THE FIRE PANEL HAS POWER BUT IS NOT FULLY FUNCTIONAL. IT SHOWS TO BE IN “TROUBLE MODE”. TO FIX IT WE ARE GOING TO HAVE TO REPLACE SOME OF OUR DETECTOR UNITS IN THE JAIL. THIS WILL BE DONE BY AN OUTSIDE COMPANY THAT WE ARE IN THE WORKS OF GETTING A CONTRACT WITH.**
- 3. GOOD NOTE: ALL FIRE EXTINGUISHERS ARE CLEARED AND UP TO DATE.**
- 4. ALL FIRE SUPPRESSION HAS BEEN UPGRADED AND UP TO DATE. IE THE HOOD VENTS ON STOVES.**



John Bel Edwards
GOVERNOR

Office of State Fire Marshal

8181 Independence Blvd. Baton Rouge, LA 70806
(225) 925-4911 (800) 256-5452 Fax (225) 925-4241



H. "Butch" Browning
FIRE MARSHAL

Inspection Report

Report # CB-19-042631-2

Deficient/Cautionary Codes cited.

Location Information					
Inspection Type	Compliance Building Inspection		Inspection Date	11/22/2021 12:55:43 PM	
Structure ID	8189	No. of Buildings	1	Facility Code	J24
Capacity	161	Year Built	1984	Construction Type	Type IIA / (111)
Building/Trade Name			Address		
BEAUREGARD PARISH JAIL			412 MAYEAUX STREET, DERIDDER, LA 70634		
Owner Information					
Owner Type	Name	Contact Phone	Contact Email		
Municipal Project	WARDEN FREDDIE DOYLE	(337) 463-3281	FDOYLEJR@BPSHERIFF.ORG		
Address					
, DERIDDER, LA 70634					
Tenant Information					
Name	Suite Number	Floor Number	Square Footage		
Occupancy Details					
Occupancy Type	Details				
Institutional	INSTITUTIONAL BUILDING TYPE: GROUP I-3 (DETENTION/CORRECTION); DETENTION/CORRECTION FACILITY TYPE: CONDITION 4				
Deficient and Cautionary Items					
Description	Code Status	Correction Date			
NFPA 101 1981 14-3.4.1 Owner shall provide and maintain a working fire alarm detection system. Currently the fire alarm is in alarm and has been silenced. No one at the facility was aware of when the alarm occurred or that the system was in alarm.	DEFICIENT	11/29/2021			
NFPA 101 1981 14-5.1 Owner shall have the electrical services inspected and serviced by a Louisiana licensed electrician. Currently there are multiple electrical deficiencies including exposed wiring, open wiring on the exterior of burned outlets, lighting/outlets hanging by wiring.	DEFICIENT	12/22/2021			
NFPA 101, 1981, 14-2-11.5 Owner shall provide all doors in a means of egress which can be readily opened in the event of an emergency. Currently the Southeast exit from the rear corridor is inoperable either by key or remote lock.	DEFICIENT	12/6/2021			
Department of Public Safety and Corrections Policy #006 Each offender shall be issued a bed and a locker. Currently several offenders do not have a locker and have subsequently obtained a large cache of items within their cell. All belonging must be stored within the locker.	DEFICIENT	12/22/2021			
NFPA 101 1981 14.2.8 Owner shall provide exit illumination and emergency lighting in means of egress. Currently there is no operable emergency lighting nor exit lights.	DEFICIENT	12/22/2021			
Comments					
IT WAS LEARNED DURING THIS INSPECTION SEVERAL NEW EMPLOYEES WERE PRESENT WHO WERE NOT AWARE OF KEY LOCATIONS AND WHICH KEYS OPERATED EXIT DOORS FOR EMERGENCY PROCEDURES. ONLY THE SHIFT SUPERVISOR WAS ABLE TO IDENTIFY PROPER KEYS.					



John Bel Edwards
GOVERNOR

Office of State Fire Marshal

8181 Independence Blvd. Baton Rouge, LA 70806
(225) 925-4911 (800) 256-5452 Fax (225) 925-4241



H. "Butch" Browning
FIRE MARSHAL

Inspection Report

Report # CB-19-042631-2

Deficient/Cautiounary Codes cited.

DEFICIENCIES CITED ON THE REPORT.

CURRENTLY THERE ARE 132 OFFENDERS HOUSED AT THIS FACILITY.

Inspector Information

Name: Justin McCullough	Badge Number: 693	Inspector Signature:
-------------------------	-------------------	----------------------

Person to whom requirements were explained

Name: Haller, Dustin	Title: Shift Supervisor	Signature:
----------------------	-------------------------	------------

For questions regarding the contents of this report, please call: (800) 554 0006

R. S. 40: 1621 Whoever fails to comply with any order issued by the Fire Marshal or his authorized representative under any provision of Part III, Chapter 7, Title 40 of the Louisiana Revised Statutes of 1950, R.S. 40:1569 excepted, shall be fined not more than five hundred dollars or imprisoned, for more than six months or both. Each day's violation of an order constitutes a separate offense and may be punished as such at the discretion of court.



John Bel Edwards
GOVERNOR

Office of State Fire Marshal

8181 Independence Blvd. Baton Rouge, LA 70806
(225) 925-4911 (800) 256-5452 Fax (225) 925-4241

Inspection Report

Report # CB-19-042631-2

Deficient/Cautionary Codes cited.

L.R.S. 40:1577 APPEAL FROM ORDER



H. "Butch" Browning
FIRE MARSHAL

When an order is made by one of the deputies or representatives of the Fire Marshal, the owner or occupant of the building or premises may, within three days, appeal to the Fire Marshal. The Fire Marshal shall, within five days, review the order and advise the owner or occupant of his decision thereon. The owner or occupant may, within five days after the making of affirming of any such order of the Fire Marshal, file an application with the Board of Review.

RULES FOR APPEALING TO THE FIRE MARSHAL BOARD OF REVIEW

- I. Any application to the Board of Review shall contain the following basic information set off in organized fashion with captions indicating that the paragraph in question contains the following basic information.
 1. The name of the applicant.
 2. A brief description of the facts.
 3. A copy of the order of the Fire Marshal which is being appealed.
 4. A reference to the section of the law or code being reviewed.
 5. A brief description of why the applicant feels the requirements of the Fire Marshal is not within the Fire Marshal's authority, or brief description of why the interpretation of the Fire Marshal is incorrect or what specific relief is required by the applicant.
 6. A list of the individuals who will be appearing before the Board, and a brief description of the testimony or information they will be providing the Board.
 7. A list of all the documents which will be introduced or provided to the Board along with a brief description of the documents, and if possible, a copy of said documents.
 8. A list of each exhibit except for documents, and a brief description of the exhibit.
- II. Whenever possible, a notice of the meeting, date and place, and the agenda will be recorded in the Louisiana Register, however, whenever that is not possible, a copy of the meeting notice including the date, time and place, and agenda of the meeting of the Board will be published in the official notices of the official state journal; furthermore, a press release containing the same information will be mailed to the official journals of the cities of Shreveport, Monroe, Lafayette, Lake Charles, Alexandria, New Orleans, and Baton Rouge and any city or town in which the meeting of the Board is to be held if it is not one of the aforementioned major cities; and the same information shall be mailed to each individual who has notified the Fire Marshal of his desire to receive a notice of such appeal.
- III. A copy of the determination of the Board as prepared by the Chairman will be mailed to each individual who requests a copy of that specific determination as well as to the applicant.
- IV. The time delays for filing an appeal shall be those specified in R.S.40:1577 and 40:1578 1 D.

Chad Firmin

From: BRANDON FLETCHER <brandonfletcherxfiles@gmail.com>
Sent: Tuesday, January 25, 2022 9:51 AM
To: Chad Firmin
Subject: Re: Health report

EXTERNAL EMAIL: Please do not click on links or attachments unless you know the content is safe.

I FINALLY GOT WITH OUR POLICE JURY REPRESENTATIVE YESTERDAY, FROM OUR MOST LATEST VISIT, WE HAVE NOT MADE ANY CORRECTIONS TO THE EXCEPTIONS. THIS IS LEADING TO THE CAUSE THAT WE ARE IN THE PROCESS OF REMOVING ALL OUR INMATES TO OTHER FACILITIES SO WE CAN BEGIN MAKING REPAIRS TO THE WHOLE JAIL.

On Fri, Jan 21, 2022 at 9:02 AM Chad Firmin <Chad.Firmin@la.gov> wrote:

Ok. Email me a copy of the report once they inspect.

From: BRANDON FLETCHER <brandonfletcherxfiles@gmail.com>
Sent: Friday, January 21, 2022 8:57 AM
To: Chad Firmin <Chad.Firmin@la.gov>
Subject: Re: Health report

EXTERNAL EMAIL: Please do not click on links or attachments unless you know the content is safe.

MAJOR FIRMIN, THE HEALTH DEPT IS COMING BACK THIS COMING WEEK FOR ANOTHER INSPECTION, AS FAR AS I KNOW WE HAVNT FIXED ANY OTHER ISSUES SINCE THE LAST VISIT

On Wed, Jan 19, 2022 at 10:07 AM Chad Firmin <Chad.Firmin@la.gov> wrote:

Any luck on any corrections and or repairs to the violations on the DHH reports? Was anything done to correct the issues?

From: BRANDON FLETCHER <brandonfletcherxfiles@gmail.com>
Sent: Tuesday, January 11, 2022 10:38 AM

To: Chad Firmin <Chad.Firmin@la.gov>

Subject: Fwd: Health report

EXTERNAL EMAIL: Please do not click on links or attachments unless you know the content is safe.

MAJOR FIRMIN, I GOT THESE EMAILED TO ME FOR OUR LAST VISIT.

----- Forwarded message -----

From: Sheriff Office <achambers@bpsheriff.org>

Date: Mon, Jan 10, 2022 at 4:28 PM

Subject: Health report

To: <brandonfletcherxfiles@gmail.com>

Sent via the Samsung Galaxy Note20 Ultra 5G, an AT&T 5G smartphone
Get [Outlook for Android](#)

SECTION III. SCOPE OF SERVICES

Beauregard Parish Jail – Cell Door Replacement

412 Bolivar Bishop Drive
DeRidder, Louisiana 70634

Contractor warrants compliance of all applicable laws and regulations.

ARTICLE 1 – SCOPE OF WORK

1. Items Included In the Scope of Work:

- 58 solid metal swinging doors with metal door frames
- 58 electromagnetic locksets to be placed at each door
- All door hardware needed to secure doors
- 7 new main door and dayroom door sliding devices
- 1 solid metal swinging door for trustee door
- 14 new interior door locks
- 1 new relay cabinet to be placed in attic
- 1 new analog control panel
- 9 new intercom stations with main controller in control room
- New key system to be broke down by block (see scope of work)

2. Excluded from Scope of Work:

- Any demo work to be done
- Conduit and wiring to be pulled for each lockset and door
- Wiring for new intercom set
- All painting on doors and cell blocks

3. Delta Block Cell Scope of work:

- Install 7 new solid metal swinging doors and door frames on each cell
- Install 7 new electromagnetic locksets at each door
- Install proper hinges and proper security hardware needed for each door
- Install locks to wiring provided at the door and in the raceway above the door. Install 7 relays in cabinet provided in the attic and Install to new analog panel in control room.

Each cell door will need to be equipped with a 2'x2' Lexan shatter proof window. A passable food slot with a lockable flap will need to be installed at each door. Each food slot will be keyed the same but different than the cell doors. All 7 cell doors shall have the same key to operate.

4. Delta Block Dayroom and Main doors:

- Replace existing main door southern lock with newer electromagnetic lock
- Replace dayroom sliding door with newer rack and pinion sliding device. Existing bar grating door will stay in place. Hook device to wiring provide, install relay for this door to cabinet provided in attic, and install on Analog control panel in control room.

- Replace existing Southern Steel lock at both the front and back door to the block with a new electromagnetic lock. Install to wiring at the door, install to new relays in cabinet in attic, and install to Analog control panel in control room
- Install new sliding device to existing dayroom door. Install device to wiring provided, install to new relay in cabinet in attic, and install to Analog panel in control room

Each of these 3 doors will remain as they are. We will only be upgrading the lock and sliding devices to each of these doors and new wiring will be ran and ready for install.

Once all doors and devices are installed, the raceway above the doors will need to be welded solid with a small flap on each side of the block for access in the future if needed.

9. Bravo Block Cell Door Scope of Work:

- Install 15 solid metal swinging doors and door frames
- Install 15 electromagnetic locksets at each door
- Install all proper security hardware and hinges at each door
- Install locks to wiring provided at the doors, install locks to 16 relays in the cabinet in the attic, and install to analog panel in control room

Each cell door will need to be equipped with a 2'x2' Lexan shatter proof window. A passable food slot with a lockable flap will need to be installed at each door. Each food slot will be keyed the same but different than the cell doors. All 15 cell doors shall have the same key to operate.

10. Bravo Block Main door and Dayroom door:

- Replace existing Southern Steel lock at both the front and back door to the block with a new electromagnetic lock. Install to wiring at the door, install to new relays in cabinet in attic, and install to Analog control panel in control room
- Install new sliding device to existing dayroom door. Install device to wiring provided, install to new relay in cabinet in attic, and install to Analog panel in control room

Each of these 3 doors will remain as they are. We will only be upgrading the lock and sliding devices to each of these doors and new wiring will be ran and ready for install.

Once all doors and devices are installed, the raceway above the doors will need to be welded solid with a small flap on each side of the block for access in the future if needed.

11. Charlie Block Cell Door Scope of Work:

- Install 16 solid metal swinging doors and door frames
- Install 16 electromagnetic locksets at each door
- Install all proper security hardware and hinges at each door
- Install locks to wiring provided at the doors, install locks to 16 relays in the cabinet in the attic, and install to analog panel in control room

Each cell door will need to be equipped with a 2'x2' Lexan shatter proof window. A passable food slot with a lockable flap will need to be installed at each door. Each food slot will be keyed the same but different than the cell doors. All 16 cell doors shall have the same key to operate.

12. Charlie Block Main door and Dayroom door:

- Replace existing Southern Steel lock at both the front and back door to the block with a new

- Install new sliding device on side exit door. Existing solid door will stay in place. Install device to wiring provided, install relay for this door to cabinet provided in attic, and install to Analog control panel in control room.

Each of these 3 doors will remain as they are. We will only be upgrading the lock and sliding devices to each of these doors and new wiring will be ran and ready to be plugged in.

Once all doors and devices are installed, the raceway above the doors will need to be welded solid with a small flap on each side of the block for access in the future if needed.

5. Echo Cell Doors Scope of Work:

- Install 4 solid metal swinging doors and door frames
- Install 4 electromagnetic locksets at each door
- Install all proper security hardware and proper hinges needed for each door
- Install locks to wiring provided at the door frames. Install 4 new relays in the cabinet provided in the attic and install to new analog panel in control room

Each cell door will need to be equipped with a 2'x2' Lexan shatter proof window. A passable food slot with a lockable flap will need to be installed at each door. Each food slot will be keyed the same but different than the cell doors. All 4 cell doors shall have the same key to operate.

6. Echo Main Door and Dayroom:

- Replace existing Southern Steel lock with newer electromagnetic lock. Install to wiring provided at the door, install to relay cabinet in the attic, install to Analog control panel in control room.
- Install new rack and pinion sliding device to existing sliding bar grating dayroom door. Install device to wiring, install to relay cabinet in attic, and install to Analog panel in control room
- Install new sliding device on side exit door to existing solid sliding door, install to new wiring, install to relay cabinet in attic, install to control panel in control room.

Each of these 3 doors will remain as they are. We will only upgrade the lock and sliding devices to each of these doors and new wiring will be run and ready for install.

Once all doors and devices are installed, the raceway above the doors will need to be welded solid with a small flap on each side of the block for access in the future if needed.

7. Alpha Block Cell Door Scope of Work:

- Install 16 solid metal swinging doors and door frames
- Install 16 electromagnetic locksets at each door
- Install all proper security hardware and hinges at each door
- Install locks to wiring provided at the doors, install locks to 16 relays in the cabinet in the attic, and install to analog panel in control room

Each cell door will need to be equipped with a 2'x2' Lexan shatter proof window. A passable food slot with a lockable flap will need to be installed at each door. Each food slot will be keyed the same but different than the cell doors. All 16 cell doors shall have the same key to operate.

8. Alpha Block Main door and Dayroom door:

electromagnetic lock. Install to wiring at the door, install to new relays in cabinet in attic, and install to Analog control panel in control room

- Install new sliding device to existing dayroom door. Install device to wiring provided, install to new relay in cabinet in attic, and install to Analog panel in control room

Each of these 3 doors will remain as they are. We will only be upgrading the lock and sliding devices to each of these doors and new wiring will be ran and ready for install.

Once all doors and devices are installed, the raceway above the doors will need to be welded solid with a small flap on each side of the block for access in the future if needed.

13. Main Entrance and Exterior Doors

Remove 8 existing Southern steel lock and install new electromagnetic lock. Install to wiring at the door, install to relay cabinet in attic, and install to Analog panel in control room

14. Trustee Dorm Door:

- Install new solid metal swinging door in place of existing door. The frame does not need to be changed, just the door. This door will need a 2'x2' Lexan shatter proof window. No food passage is needed for this door.
- Remove the Southern Steel lock and replace with new electromagnetic lock. Install to wiring at the doors, install to relay cabinet in attic, and install to Analog control panel in control room.
- Install proper security hardware and hinges.
- Install lockable food slot pass

The main doors and exterior doors will all remain the same existing doors. We will only be upgrading and changing locks to each of these doors.

15. Electronics, Analog Control Panel, and Intercom system

- Provide an analog control panel with basic push button system and a LED red and green light above each button
- Provided new relays for each door and lock to be installed in cabinet in the attic
- Provide proper connectors and splices to be made at each spot where necessary

The new analog panel will need to be a aluminum metal style panel and will be laid out according to each block and door number and also include the main doors. A list of doors will be included on the next sheet. A relay cabinet will be placed and installed and located in the attic above the control room. All wires will be running from each door to that cabinet, then down to the new panel inside the control room.

16. Intercom System

- Provide a total of 10 intercom speakers. These need to be institutional style for inside the jail.
- Provide a master control in the control room.
- There will be a intercom at the front door, back door, laundry, kitchen, delta block, echo block, T1 dorm, T2 dorm, visitation, and back gate.